

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12831-01-AM  
**Monitoring Date:** 19/1/2021  
**Received Date:** 19/1/2021  
**Analysis Date:** 19/1/2021  
**Report Date:** 19/1/2021  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Redmond Policarpio  
**Sampled By:** Jake Gunns  
**Approved Counter:** Gonzalo Serna Diaz  
**Approved Signatory:** Michael Fernandez

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12831/1	Service road, exclusion zone, southern fence	1	07:16	14:30	1.04	1.04	1	100	<0.01
40-12831/2	Service road, exclusion zone, eastern fence	1	07:17	14:31	1.04	1.04	0	100	<0.01
40-12831/3	Service road, exclusion zone, western fence	1	07:20	14:32	1.04	1.04	1	100	<0.01
40-12831/4	Service road, exclusion zone, northern fence, opposite wet decontamination exit	1	07:24	14:33	1.04	1.04	0	100	<0.01
40-12831/5	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12831-01-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12831-02-AM  
**Monitoring Date:** 20/1/2021  
**Received Date:** 20/1/2021  
**Analysis Date:** 21/1/2021  
**Report Date:** 21/1/2021  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Redmond Policarpio  
**Sampled By:** Gonzalo Serna Diaz  
**Approved Counter:** Gonzalo Serna Diaz  
**Approved Signatory:** Luke Heckenberg

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12831/6	Service road, exclusion zone, southern fence	1	07:00	14:30	0.97	0.97	1	100	<0.01
40-12831/7	Service road, exclusion zone, eastern fence	1	07:02	14:34	0.97	0.97	0	100	<0.01
40-12831/8	Service road, exclusion zone, western fence	1	07:04	14:38	0.97	0.97	0	100	<0.01
40-12831/9	Service road, exclusion zone, northern fence, opposite wet decontamination exit	1	07:06	14:40	0.97	0.97	1	100	<0.01
40-12831/10	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12831-02-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12541-12-AM  
**Monitoring Date:** 20/11/2020  
**Received Date:** 20/11/2020  
**Analysis Date:** 20/11/2020  
**Report Date:** 23/11/2020  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Omar Ghanem  
**Sampled By:** Jake Gunns  
**Approved Counter:** Jake Gunns  
**Approved Signatory:** Nathan Crouch

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/56	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:29	1.04	1.04	1	100	<0.01
40-12541/57	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:30	1.04	1.04	0	100	<0.01
40-12541/58	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:32	1.04	1.04	0	100	<0.01
40-12541/59	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:33	1.04	1.04	0	100	<0.01
40-12541/60	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-12-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12831-03-AM  
**Monitoring Date:** 21/1/2021  
**Received Date:** 21/1/2021  
**Analysis Date:** 21/1/2021  
**Report Date:** 21/1/2021  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Redmond Policarpio  
**Sampled By:** Gonzalo Serna Diaz  
**Approved Counter:** Jake Gunns  
**Approved Signatory:** Luke Heckenberg

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12831/11	Service road, exclusion zone, southern fence	1	07:00	14:44	0.97	0.97	0	100	<0.01
40-12831/12	Service road, exclusion zone, eastern fence	1	07:01	14:42	0.97	0.97	0	100	<0.01
40-12831/13	Service road, exclusion zone, western fence	1	07:02	14:47	0.97	0.97	0	100	<0.01
40-12831/14	Service road, exclusion zone, northern fence, opposite wet decontamination exit	1	07:03	14:50	0.97	0.97	0	100	<0.01
40-12831/15	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12831-03-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12831-04-AM  
**Monitoring Date:** 22/1/2021  
**Received Date:** 22/1/2021  
**Analysis Date:** 22/1/2021  
**Report Date:** 22/1/2021  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Redmond Policarpio  
**Sampled By:** Jake Gunns  
**Approved Counter:** Jake Gunns  
**Approved Signatory:** Luke Heckenberg

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12831/16	Service road, exclusion zone, southern fence	1	07:00	15:25	1.04	1.04	0	100	<0.01
40-12831/17	Service road, exclusion zone, eastern fence	1	07:01	14:26	1.04	1.04	0	100	<0.01
40-12831/18	Service road, exclusion zone, western fence	1	07:02	14:28	1.04	1.04	0	100	<0.01
40-12831/19	Service road, exclusion zone, northern fence, opposite wet decontamination exit	1	07:03	14:30	1.04	1.04	0	100	<0.01
40-12831/20	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12831-04-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12541-13-AM  
**Monitoring Date:** 23/11/2020  
**Received Date:** 23/11/2020  
**Analysis Date:** 23/11/2020  
**Report Date:** 23/11/2020  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Omar Ghanem  
**Sampled By:** Jake Gunns  
**Approved Counter:** Jake Gunns  
**Approved Signatory:** Luke Heckenberg

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/61	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:01	14:42	1.04	1.04	0	100	<0.01
40-12541/62	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:03	14:44	1.04	1.04	0	100	<0.01
40-12541/63	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:05	14:45	1.04	1.04	0	100	<0.01
40-12541/64	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:07	14:46	1.04	1.04	0	100	<0.01
40-12541/65	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-13-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12541-14-AM  
**Monitoring Date:** 24/11/2020  
**Received Date:** 24/11/2020  
**Analysis Date:** 24/11/2020  
**Report Date:** 24/11/2020  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Omar Ghanem  
**Sampled By:** Jake Gunns  
**Approved Counter:** Jake Gunns  
**Approved Signatory:** Luke Heckenberg

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/66	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:45	1.02	1.02	0	100	<0.01
40-12541/67	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:47	1.02	1.02	0	100	<0.01
40-12541/68	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:48	1.02	1.02	0	100	<0.01
40-12541/69	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:50	1.02	1.02	1	100	<0.01
40-12541/70	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-14-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-12831-05-AM  
**Monitoring Date:** 27/1/2021  
**Received Date:** 27/1/2021  
**Analysis Date:** 27/1/2021  
**Report Date:** 27/1/2021  
**Site Address:** Concord Repatriation Hospital,  
 Hospital Road  
 Concord NSW 2139  
**Client Name:** N. Moit & Sons (NSW) Pty. Ltd.  
**Client Address:** 142 Wicks Road  
 Macquarie Park NSW 2113

**Client Contact:** Redmond Policarpio  
**Sampled By:** Jake Gunns  
**Approved Counter:** Jake Gunns  
**Approved Signatory:** Luke Heckenberg

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12831/21	Service road, exclusion zone, southern fence	1	07:21	14:38	1.04	1.04	0	100	<0.01
40-12831/22	Service road, exclusion zone, eastern fence, opposite wet decontamination exit	1	07:19	14:36	1.04	1.04	0	100	<0.01
40-12831/23	Service road, exclusion zone, western fence	1	07:24	14:40	1.04	1.04	0	100	<0.01
40-12831/24	Service road, exclusion zone, northern fence	1	07:23	14:43	1.04	1.04	1	100	<0.01
40-12831/25	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12831-05-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.